

## Declaration of Conformity

Issued by Manufacturer  
Hoffman Enclosures, Inc.  
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.  
declare at our sole responsibility, that these devices are designed and constructed according to  
the fundamental safety and health requirements.

**Enclosure Models:** A\*\*\*\*\*LP, A\*\*\*\*\*LPG, A\*\*\*\*\*ULP, A\*\*\*\*\*ULPG  
(Bulletin A12L)

**Equipment Description:** Floormount Mild Steel Enclosure

**Enclosure Rating :** NEMA / UL / cUL Type 12, 3R

Standard product may be labeled 3R with instruction: "For Type 3R applications, two holes  
0.250 in. diameter need to be drilled at the bottom of the enclosure in diagonal corners for  
drainage."

**Enclosure Certification:** UL508A Listed E61997

File E61997 Vol. 1 Sec. 21 Page 1 Issued: 5-12-97  
and Report Revised: 8-15-97

### DESCRIPTION

#### PRODUCT COVERED:

\* Type 4, 4X, 12 Floor/Wall-Mount enclosures; Bulletin No. A4L, A4S, A12L, A12S,  
A21 and A21S.

**Applicable Standards:** UL508A Industrial Control Panel Enclosure  
UL 50 Enclosures for Electrical Equipment, Non-  
Environmental Considerations  
UL 50E Enclosures for Electrical Equipment, Environmental  
Considerations  
cUL to CSA C22.2 No. 14, 94.1 and 94.2  
NEMA250 Enclosures for Electrical Equipment (1000 Volts Maximum)

**Authorized by:**



2/18/2022

**Tom Hurney**

**Date**

Technology Mgr., Product Compliance and Approvals

Subject to Change Without Notice

DOC: CERT-00034 D



October 20, 2015

Mr. Glen Kampa  
HOFFMAN ENCLOSURES, INC.  
2100 Hoffman Way  
Anoka, MN 55303

Our Reference: File E61997

**Subject: Reason that Listed UL508A (CCN: NITW/NITW7) enclosures do not have model nos.**

Dear Mr. Kampa:

You recently asked why enclosure model numbers do not appear on your UL Certification or in the Online Certification Directory which can be found at [www.ul.com](http://www.ul.com). Your file E61997 is covered under the category for Industrial Control Panels, UL category control number (CCN) NITW. This category also covers Industrial Control Panel Enclosures. NITW is what we refer to as a Type L category.

Products covered under Type L categories are not required to be marked with a Model, Catalog or Part Number as are products covered under Type R categories (Type R service covers many Listed products and all Recognized Components (like yours covered under NITW2)). Because of this, we're not allowed to add Model numbers to our Listing Information System which populates the OCD.

It is important to note that the presence of the UL Listing Mark on the product is evidence that it is Listed. Appearance of a Model Number in the OCD is not a substitute for that.

Please let me know if you have any questions.

If you have any questions, please do not hesitate to contact us.

Your business is very important to us and if there is any additional information that we may provide to you about the investigation or UL's other services, please do not hesitate to contact us.

Sincerely,

*Nicholas Boten*

Reviewed by:

*William Bartunek*

Nicholas Boten  
Engineering Associate  
Tel: 847-664-3279  
E-mail: [nicholas.f.boten@ul.com](mailto:nicholas.f.boten@ul.com)

William Bartunek  
Senior Staff Engineer  
Energy & Power Technologies  
E-mail: [william.n.bartunek@ul.com](mailto:william.n.bartunek@ul.com)

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150914-E61997  
**Report Reference** E61997-19970512  
**Issue Date** 2015-SEPTEMBER-14

**Issued to:** PENTAIR TECHNICAL PRODUCTS  
2100 HOFFMAN WAY  
ANOKA MN 55303-1738

**This is to certify that representative samples of** INDUSTRIAL CONTROL PANELS  
Type 4, 4X, 12 Floor/Wall-Mount enclosures; Bulletin No. A4L, A4S, A12L, A12S, A21 and A21S.


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 508A, Industrial Control Panels.  
CSA C22.2. No. 14, Industrial Control Equipment.

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/about/locations](http://www.ul.com/about/locations)



