

Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.

2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.

declare at our sole responsibility, that these devices are designed and constructed according to the fundamental safety and health requirements.

Enclosure Models: FxSCSS (where “x” is the height, width, length) (Bulletin F24)

Equipment Description: TYPE 4X WIRE TROUGH

Enclosure Rating : NEMA / UL / cUL Type 3, 3R, 4, 4X, 12

Enclosure Certification: UL870A Listed E27524

Applicable Standards: UL 870 Wireway, Auxiliary Gutters and Associated Fittings
UL 50E Enclosures for Electrical Equipment, Environmental Considerations
CSA C22.2 No 26-13 Construction and Test of Wireways, Auxiliary Gutters and Associated Fittings
cUL to CSA C22.2 No. 94.2-15 Enclosures for Electrical Equipment, Environmental Considerations

File E27524

Vol. 1

Sec. 6

Page 1

and Report

Issued: 2015-12-15

Revised: 2015-12-22

PRODUCT COVERED:

USL, CNL Auxiliary gutters, UL Type 4/4X. Part Nos. F, followed by -44XXSCSS, -66XXSCSS, -88XXSCSS, -1212XXSCSS, -####XXSCSS, where XX is any two digit number from 01 to 120, may be followed by SCSS; where ##### may indicate any size that falls between the “-44” and “-1212” sizes.

Authorized by:



3/21/2018 (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

CERTIFICATE OF COMPLIANCE

Certificate Number 20151229-E27524
Report Reference E27524-20151215
Issue Date 2015-DECEMBER-29

Issued to: PENTAIR TECHNICAL PRODUCTS
2100 HOFFMAN WAY
ANOKA MN 55303-1738

**This is to certify that
representative samples of**

WIREWAY, AUXILIARY GUTTERS AND ASSOCIATED
FITTINGS

UL Type 4/4X. Part Nos. F, followed by -44XXSCSS, -
66XXSCSS, -88XXSCSS, -1212XXSCSS, -####XXSCSS,
where XX is any two digit number from 01 to 120, may be
followed by SCSS; where #### may indicate any size that
falls between the "-44" and "-1212" sizes.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 870, Wireways, Auxiliary Gutters, and Associated
Fittings.
CSA C22.2 No. 26-13, CONSTRUCTION AND TEST OF
WIREWAYS, AUXILIARY GUTTERS AND ASSOCIATED
FITTINGS
UL 50E & CSA C22.2 No. 94.2-15, Enclosures for Electrical
Equipment, Environmental Considerations.

Additional Information:

See the UL Online Certifications Directory
at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



Subject to Change Without Notice

DOC: CERT-00239 B