

Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.
declare at our sole responsibility, that these devices are designed and constructed according to
the fundamental safety and health requirements.

Enclosure Models: N16****G***, T15****G*** (Bulletin MCLG)
Equipment Description: Hoffman Compact Indoor/Outdoor Air Conditioner
Enclosure Rating : NEMA / UL / cUL Type 12, 3R, 4, 4X optional
Enclosure Certification: UL Listed SA6453

File SA6453 Vol. 1 Sec. 28 Page 1 Issued: 2004-04-30
and Report Revised: 2015-10-09

DESCRIPTION

PRODUCT COVERED:

USL, CNL Special purpose air conditioner, Model T15-01AB-GXXX and N16-01AB-GXXX, with suffixes that identify options limited to those addressed in this Report and the following:

See Certificate of Compliance on following pages

Applicable Standards: UL 484 "Room Air Conditioners"
CSA-C22.2 No. 117 "Room Air Conditioners"
CSA-C22.2 No. 236 "Heating and Cooling Equipment"
CSA/UL 60335-1 "Safety of Household and Similar Electrical Appliances, Part 1: General Requirements"
CSA/UL 60335-2-40 "Household and Similar Electrical Appliances, Part 2-40: Particular Requirements for Electrical Heat Pumps, Air-Conditioners and Dehumidifiers"

Authorized by:



11/21/2019 (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

CERTIFICATE OF COMPLIANCE

Certificate Number 20190814-SA6453
Report Reference SA6453-20040430
Issue Date 2019-AUGUST-14

Issued to: Hoffman Enclosures Inc
2100 Hoffman Way
Anoka MN 55303-1738

This certificate confirms that representative samples of AIR CONDITIONERS, SPECIAL PURPOSE
See Addendum Page for Models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 484, Room Air Conditioners
CSA C22.2 No. 117-1970, Room Air Conditioners

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190814-SA6453
Report Reference SA6453-20040430
Issue Date 2019-AUGUST-14


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model T15-01AB-GXXX and N16-01AB-GXXX, with suffixes that identify options limited to those addressed in this Report and the following:

Paint Color
Condenser Air Deflectors
Coating on Coils
Coating on Tubing
Outdoor Use Application

“A” represents 1, 2, 4, 5 and 6 (115 V, 230 V, exceeds 240 V, 100 V, and 200 V respectively). “B” represents 5 and 6 (50 Hz only and 50/60 Hz respectively).

Note: N16-01AB is identical to T15-02AB with the exception of overall unit dimensions and other specific differences noted in this report.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

