

## Declaration of Conformity

Issued by Manufacturer  
Hoffman Enclosures, Inc.  
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.  
declare at our sole responsibility, that these devices are designed and constructed according to  
the fundamental safety and health requirements.

**Enclosure Models:** G2804\*\*G\*\*\*, G2806\*\*G\*\*\* (Bulletin MCLG)  
**Equipment Description:** Hoffman SpectraCool Indoor/Outdoor Air Conditioner  
**Enclosure Rating :** NEMA / UL / cUL Type 12, 3R, 4, 4X optional  
**Enclosure Certification:** UL Listed SA6453

File SA6453      Vol. 1      Sec. 33      Page 1      Issued: 2010-12-15  
and Report      Revised: 2015-11-12

### DESCRIPTION

#### PRODUCT COVERED:

USL/CNL: Special purpose air conditioners Model G28-04AB-GXXX, G28-06AB-GXXX, with  
suffix numbers that will identify various options or combinations of  
options limited to those addressed in this Report and the following:

*See Certificate of Compliance on following pages*

**Applicable Standards:** UL 484 "Room Air Conditioners"  
CSA-C22.2 No. 117 "Room Air Conditioners"  
CSA-C22.2 No. 236 "Heating and Cooling Equipment"  
CSA/UL 60335-1 "Safety of Household and Similar Electrical  
Appliances, Part 1: General Requirements"  
CSA/UL 60335-2-40 "Household and Similar Electrical Appliances,  
Part 2-40: Particular Requirements for Electrical Heat Pumps, Air-  
Conditioners and Dehumidifiers"

Authorized by:



11/21/2019 (today's date)

**Glen Kampa**

**Date**

Senior Regulatory Engineer

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190814-SA6453  
**Report Reference** SA6453-20101215  
**Issue Date** 2019-AUGUST-14

**Issued to:** Hoffman Enclosures Inc  
2100 Hoffman Way  
Anoka MN 55303-1738

**This certificate confirms that representative samples of** AIR CONDITIONERS, SPECIAL PURPOSE  
See Addendum Page for Models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 484, Room Air Conditioners  
CSA C22.2 No. 117-1970, Room Air Conditioners

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about-us/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190814-SA6453  
**Report Reference** SA6453-20101215  
**Issue Date** 2019-AUGUST-14


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model G28-04AB-GXXX, G28-06AB-GXXX, with suffix numbers that will identify various options or combinations of options limited to those addressed in this Report and the following:

Paint color  
Lift lugs  
Coating on coils  
Coating on tubing  
Condenser air deflectors  
Convenience outlet

"A" represents 1, 2, 4, 5 and 6(115V, 208-230V, exceeds 230V, 100V, and 200V respectively) for Vac models. "B" represents 5 and 6(50 Hz only and 50/60 Hz respectively) for Vac models.

"AB" represents 48 (48 VDC) for VDC models.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

